

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3625-0324:106 Page 1 of 1

CATEGORY: Exit Door Accessories

LISTEE: Security Door Controls, 3580 Willow Lane, Westlake Village, CA 91361
*Contact: David Geringer (808) 494-0622 Fax (805) 494-8680

DESIGN: Model MSB550 exit bar. Unit is an accessory intended for use with separately listed burglary resistant electric locking device. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 to 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable code and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as access control accessory to be used with separately listed compatible burglary resistant electric locking mechanisms to prevent unauthorized entry where permitted per code. For non-rated doors and for indoor use only. Authority having jurisdiction shall be consulted prior to installation.

NOTE: Not intended to replace panic hardware.

*Rev. 05-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 15, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager